

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources
Sixth Floor – L & C Annex
401 Church Street
Nashville, TN 37243

MS. HEATHER GILMORE
ENVIRONMENTAL MANAGER
25 WEST CEDAR STREET
PENSACOLA, FL 32502
e-copy: hgilmore@circlek.com
DSCHMIDT@PANGEAN-CMD.COM
Monya.Bradley@tn.gov
Mark.A.Jordan@tn.gov

UST Groundwater Remediation NPDES General Permit
Notice of Coverage Fact Sheet

The Division of Water Resources received from your company a Notice of Intent (NOI) to be covered under the General NPDES Permit for Discharges of Treated Groundwater Associated with Underground Storage Tank Remediation (UST GP). The effective date for the new UST GP is March 1, 2008, and the expiration date is February 14, 2013. **We have recorded site information and are hereby notifying you that this groundwater remediation site is covered under the UST GP.**

Enclosed with this fact sheet you will find a Notice of Coverage (NOC) with the permit tracking number (TNG830201), facility's name, address and receiving stream information that apply to your facility/site. In order to get a copy of the UST GP requirements we ask you to visit our web site: <http://www.tn.gov/environment/permits/ustnpdes.shtml>.

We will provide you with a printed copy of the UST GP only upon your request.


At our web site, you will be able to download permit requirements, as well as permit rationale, Notice of Determination, guidance documents and find links to relevant web sites. If you do not have access to the web, or have other questions, call us at (888) 891-TDEC or contact us by E-mail at Jim.McAdoo@tn.gov.

Sincerely,



Vojin Janjic, Manager
Water-based Systems

Parameter	Effluent Limitation	Sample Type	Monitoring Frequency
Flow	Report in MGD	Instantaneous	Quarterly
Benzene	0.005 mg/L as a daily max. concentration	Grab	Quarterly
Ethyl benzene	0.010 mg/L as a daily max. concentration	Grab	Quarterly
Toluene	0.010 mg/L as a daily max. concentration	Grab	Quarterly
Xylene	0.010 mg/L as a daily max. concentration	Grab	Quarterly
Lead, total recoverable	0.45 mg/L as a daily max. concentration	Grab	Quarterly
Lead, total recoverable	0.017 mg/L as a monthly average concentration	Grab	Quarterly
Total Suspended Solids (TSS)	40.0 mg/L as a daily max. concentration	Grab	Quarterly
Floating Material, Color, Foam and Oil Sheen	No distinctly visible floating scum, oil or other matter	Visual	Quarterly
pH	6.5 - 9.0 (range)	Grab	Quarterly
Dilution factor	1		
IC25	Survival, Reproduction, & Growth in 100% effluent	Composite	see subpart 5 c)



Tracking No. TNG830201

General NPDES Permit for Discharges of Treated Groundwater Associated with
UNDERGROUND STORAGE TANK REMEDIATION

Effective March 1, 2008, through February 14, 2013

Tennessee Department of Environment and Conservation
Division of Water Resources
401 Church Street
6th Floor, L&C Annex
Nashville, Tennessee 37243-1534

Under authority of the Tennessee Water Quality Control Act of 1977 (T.C.A. 69-3-101 et seq.) and the delegation of authority from the United States Environmental Protection Agency under the Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (33 U.S.C. 1251, et seq.):

Discharger: **Circle K Store (#2703132)**

is authorized to discharge: treated groundwater associated with underground storage tank remediation

from a site located at: **4789 East Shelby Drive in Memphis, Shelby County**

to receiving waters named: **John's Creek**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

Coverage under this general permit shall become effective on **July 1, 2013**

and shall expire on **May 31, 2018**

Notice of Coverage issued: **June 25, 2013**

UST General Permit is located at <http://www.tn.gov/environment/permits/ustnpdes.shtml>